

EDNV Parking, Firerescue and Safety

1. General

The measures relating to fire protection in accordance with NfL 2023-1-2792 Paragraph 3.2, non-commercial traffic in accordance with Section 49 LuftVZO and the safety of the special landing site are described below.

The contact person for safety and fire protection measures is the operations manager appointed by the airport owner and operator (Mr. Hermann Selbertinger):

Mr. Helmut Frank

Telephone 0171 440 7342

Email: ednv@hfcp.de

2. Implementation of NfL 2023-1-2792

The EDNV airfield is a special landing site with non-commercial traffic at set times according to PPR rules.


During operating times without an operations manager, two fire extinguishers were installed next to the petrol station in a freely accessible manner in accordance with NfL 2023-1-2792 paragraph 4.2.1. The extinguishing agent containers are sealed and are regularly checked by the appointed operations manager.

Figure 1



EDNV Parking, Firerescue and Safety

3. Parking and fire extinguisher placement



Diese Karte ist über die Internetseite ednv.de publiziert und frei einsehbar.

4. Alarm plans

The following alarm plan has been placed in several places.
Figure 4

ALARMPLAN

Verhalten bei Bränden und bei Unfällen

Verhalten im Brandfall

1. Notruf

Feuerwehr:	Tel. 112
Polizei:	Tel. 110
Unternehmer/in:	Tel. 0171 1786198

Inhalt der Meldung: **Wo brennt es? Was brennt? Sind Menschen in Gefahr? Wer meldet? Warten auf Rückfragen!**

2. Menschenrettung – geht vor Brandbekämpfung

3. Versorgungsmedien abstellen

Heizung:	
Strom/intern:	
Gas/intern:	
Wasser/intern:	
Strom/extern:	Tel. --
Gas/extern:	Tel. --
Wasser/extern:	Tel.

4. Löschversuch unternehmen – ggf. brennbares Material beseitigen
Feuerschutzabschlüsse, Türen und Fenster schließen!
 Nächster Feuerlöscher:

5. Feuerwehr einweisen, Verkehrswege freihalten, am Sammelplatz einfinden

Verhalten bei Unfällen

Notruf: Rettungsleitstelle: Tel. 112 oder |

Inhalt der Meldung: **Wo ist der Unfallort? Was ist geschehen? Wie viele Verletzte? Welche Verletzungen? Wer ruft an?**

Ersthelfer/in:	Tel.
Verbandkasten:	Tel.
Arzt/Ärztin:	Tel.
D-Arzt/D-Ärztin:	Tel.
Augenarzt/-ärztin:	Tel.
Betriebsarzt/-ärztin:	Tel.
Sicherheitsfachkraft:	Tel.
Berufsgenossenschaft:	Tel.
Amf für Arbeitsschutz:	Tel.

Bitte Bagatelle-Verletzung wegen evtl. auftretender Folgeschäden im Verbandbuch eintragen!

EDNV Parking, Firerescue and Safety

5. Video surveillance CCTV

The airport is equipped with several video cameras with motion sensors and night vision function.

This mainly monitors the

- runway 06/24
- access from the east
- petrol station

At the access and at the hangar there are appropriate signs for surveillance.

